



REMPACEMENT DE FENÊTRES, BIBLIOTHÈQUE PUBLIQUE MGR-W.-J.-
CONWAY

MGR-W.-J.-CONWAY PUBLIC LIBRARY WINDOW REPLACEMENT

Appel d'offres 2025-062 / Tender Call 2025-062

ADDENDA 2 / ADDENDUM 2

1. **Contrary to the information indicated on drawings A2 and A3, all windows for this project are fix, none are awning operable.**
2. In section 08 44 13, GLAZED ALUMINUM CURTAIN WALLS, of the addenda #1, please delete completely the article 1.6.3.6 as follow:

~~.6 Shop drawings to be stamped by a Professional Structural Engineer licensed at the place where the Project is located.~~

3. In section 08 44 13, GLAZED ALUMINUM CURTAIN WALLS, of the addenda #1, please replace the article 2.9.2.1 with the following:

.1 Red (Terra Cotta): **Custom Painted Duranar XL Paint Finish or equivalent**
~~AA-M12C22A44 Class I. (exterior)~~

4. In section 08 80 00, GLAZING, please delete completely the article 3.4 as follow:

~~3.4 TESTING~~


~~.1 Testing and reporting will be carried out by an independent testing agency selected by the Engineer Architect.~~

~~.2 Coordinate and assist testing agency, and allow access to the Work.~~

A signed copy of this addendum must be included with the tender submission.

Une copie signée de cet addenda doit être incluse avec la proposition de l'appel d'offres.

Tenderer's signature
Signature du soumissionnaire



Guy Plourde, Development
February 11, 2025